

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source
				Low	High			
Disinfectants & Disinfection By-Products								
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)								
Chlorine (as Cl ₂) (ppm)	4	4	.59	.43	.59	2021	No	Water additive used to control microbes
Haloacetic Acids (HAA5) (ppb)	NA	60	16.7	NA	NA	2021	No	By-product of drinking water chlorination
TTHMs [Total Trihalomethanes] (ppb)	NA	80	22.9	NA	NA	2021	No	By-product of drinking water disinfection
Inorganic Contaminants								
Barium (ppm)	2	2	.007	NA	NA	2019	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Microbiological Contaminants								
Turbidity (NTU)	NA	1.0	.029	NA	NA	2021	No	Soil runoff
.029% of the samples were below the TT value of 1. A value less than 95% constitutes a TT violation. The highest single measurement was .29. Any measurement in excess of 5 is a violation unless otherwise approved by the state.								
Radioactive Contaminants								
Alpha emitters (pCi/L)	0	15	3.85	NA	NA	2018	No	Erosion of natural deposits
Radium (combined 226/228) (pCi/L)	0	5	.248	NA	NA	2018	No	Erosion of natural deposits
Uranium (ug/L)	0	30	3.35	NA	NA	2018	No	Erosion of natural deposits
Contaminants	MCLG	AL	Your Water	Sample Date	# Samples Exceeding AL	Exceeds AL	Typical Source	
Inorganic Contaminants								
Copper - action level at consumer taps (ppm)	1.3	1.3	.279	2019		No	Corrosion of household plumbing systems; Erosion of natural deposits	
Lead - action level at consumer taps (ppb)	0	15	4	2019		No	Corrosion of household plumbing systems; Erosion of natural deposits	